

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 54/2026

Dated: 7.2.26

It is certified that an inspection team headed by M.I. CIRAJ, HEALTH INSPECTOR

(Name of Officers with designation) from FHC KEEZHMAAD PHED

inspected the AMAL PUBLIC SCHOOL, CHALAKKAL

(Name & Address of the school) on 7.2.26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ALY/B/9648 dated 24.11.2025


of KERALA WATER AUTHORITY, ALUVA (PHED Lab) certified that

the AMAL PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 6.2.27



Signature with Seal: 
Name: M.I. CIRAJ
Designation: HEALTH INSPECTOR
Name & Address of the Office / Department:

To PRINCIPAL
AMAL PUBLIC SCHOOL
(Name & Address of the Institution)

Health Inspector
Family Health Centre
Keezhmad

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



TC-12118
Telephone:0484-2623576
email:-qcldaluva@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB,ALUVA -683101
WATER TEST-BACTERIOLOGY REPORT

Report No: ALY/B/9648

Report Issue Date: 24.11.2025

Customer Name & Address		Date of Receipt of Payment	12.11.25	
Amal Public School Azhar Nagar Chalakkal Marampilly		Date of Sample received	19.11.25	
		Sample given by	MO, FHC Keezhmad	
		Sample Code	ALY/B/9648	
		Sample Name	Drinking Water	
		Sample Condition	Fit For Analysis	
		Source of Sample	Well	
		Sample Quantity	250ml	
		Test performing dates :		From :19.11.25 to 20.11.25
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent
2	E-Coli	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 4 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory


Analyzed By

[Signature]

Authorized By Quality Manager

[Signature]

End of Report



KWA/QCDL/ALY/0

Issue Date : 04.10.2020

Rev.No: 06

Rev.Date : 15/07/2025

Page 2 of 2

QUALITY MANAGER
KWA, QUALITY CONTROL DISTRICT LAB
ERNAKULAM, ALUVA - 683 101